



**The facility-maintained compliance on all parameters!**

## **Collection System**

### **Activity/task were performed during the month:**

- There were 198 locates with 10 being emergency during the month of March.
- All Lift station were inspected weekly during the month, with increased attention given to electrical condition to control panels and pumps.
- A total of nine (9) rain events occurred during the month, The largest events were on March 25 at the WWTP. Total Rainfall for the month at the facility Was 7.1”.
- 3450’ liner feet main line was flushed during the month.
- 75’ linear feet main line footage was Televised during the month.

### **Managers Notes:**

Operations continue to improve with increased emphasis on lift station/collection system improvements.

The new team member collection system experience HAS reduced total dependency on lift station and plant service/repair needs.

### **Training:**

Lift station maintenance and safety training was performed during the month.

### **Staff :**

Independence continues to increase due to the efforts of the utility staff and their willingness to learn and accept new responsibilities. Two staff members tested and achieved the operator certifications.